



Ripon Consolidated Fire District

142 S. Stockton Ave. Ripon, CA 95366

Phone 209-599-4209 Fax 209-599-2847

Fire Chief
Dennis Bitters

FIRE CONSTRUCTION PERMIT – CHECK LIST

The following information and documentation must be submitted to Development Services before your application can be processed.

	Check-Off
1. One completed Application	
2. The submittals shall be per the following:	
a. Submit only three (3) complete sets of plans.	
b. Fire Sprinkler plans and calculations shall include all items per Chapter 6 of NFPA 13.	
c. All fire suppression systems shall be designed per the applicable current adopted codes.	
d. A licensed Fire Protection Engineer or the installation contractor shall wet sign all plans.	
e. The California State License Number shall be on the plans.	
f. The preferred paper size is 24" x 36".	
g. Cover sheet of plans shall have a space for approval stamps in the lower Right hand corner.	
h. Sets shall be fastened together as individual sets	
i. Reference sheets shall be included in sets	
j. Hydraulic calculations shall be in sets. (System 1, 2, 4, 4, etc. as a set.) (Three (3) sets of each only).	
k. Hydraulic calculations shall have a cover sheet for approval stamps.	
l. Material submittals shall annotate the specific items being installed.	
m. If the underground is not a part of the submittal, an explanatory statement or an underground reference set of plans shall accompany the submittal.	
n. Plans for warehousing must show storage arrangements (shell building excluded).	